

§ 52.48

10 CFR Ch. I (1–12 Edition)

(c) This paragraph applies, according to its provisions, to particular applications:

(1) An application for certification of a nuclear power reactor design that is an evolutionary change from light-water reactor designs of plants that have been licensed and in commercial operation before April 18, 1989, must provide an essentially complete nuclear power plant design except for site-specific elements such as the service water intake structure and the ultimate heat sink;

(2) An application for certification of a nuclear power reactor design that differs significantly from the light-water reactor designs described in paragraph (c)(1) of this section or uses simplified, inherent, passive, or other innovative means to accomplish its safety functions must provide an essentially complete nuclear power reactor design except for site-specific elements such as the service water intake structure and the ultimate heat sink, and must meet the requirements of 10 CFR 50.43(e); and

(3) An application for certification of a modular nuclear power reactor design must describe and analyze the possible operating configurations of the reactor modules with common systems, interface requirements, and system interactions. The final safety analysis must also account for differences among the configurations, including any restrictions that will be necessary during the construction and startup of a given module to ensure the safe operation of any module already operating.

(d) Each applicant for a standard design certification under this part shall protect Safeguards Information against unauthorized disclosure in accordance with the requirements in §§ 73.21 and 73.22 of this chapter, as applicable.

[72 FR 49517, Aug. 28, 2007, as amended at 73 FR 63571, Oct. 24, 2008; 74 FR 28147, June 12, 2009]

§ 52.48 Standards for review of applications.

Applications filed under this subpart will be reviewed for compliance with the standards set out in 10 CFR parts 20, 50 and its appendices, 51, 73, and 100.

§ 52.51 Administrative review of applications.

(a) A standard design certification is a rule that will be issued in accordance with the provisions of subpart H of 10 CFR part 2, as supplemented by the provisions of this section. The Commission shall initiate the rulemaking after an application has been filed under § 52.45 and shall specify the procedures to be used for the rulemaking. The notice of proposed rulemaking published in the FEDERAL REGISTER must provide an opportunity for the submission of comments on the proposed design certification rule. If, at the time a proposed design certification rule is published in the FEDERAL REGISTER under this paragraph (a), the Commission decides that a legislative hearing should be held, the information required by 10 CFR 2.1502(c) must be included in the FEDERAL REGISTER document for the proposed design certification.

(b) Following the submission of comments on the proposed design certification rule, the Commission may, at its discretion, hold a legislative hearing under the procedures in subpart O of part 2 of this chapter. The Commission shall publish a document in the FEDERAL REGISTER of its decision to hold a legislative hearing. The document shall contain the information specified in paragraph (c) of this section, and specify whether the Commission or a presiding officer will conduct the legislative hearing.

(c) Notwithstanding anything in 10 CFR 2.390 to the contrary, proprietary information will be protected in the same manner and to the same extent as proprietary information submitted in connection with applications for licenses, provided that the design certification shall be published in Chapter I of this title.

§ 52.53 Referral to the Advisory Committee on Reactor Safeguards (ACRS).

The Commission shall refer a copy of the application to the ACRS. The ACRS shall report on those portions of the application which concern safety.